


## CURB AND GUTTER GENERAL NOTES:

1. Contraction joints shall be placed ten (10) feet on centers and shall be saw cut to a minimum depth of two (2) inches from front to back within twenty four (24) hours of concrete placement.
2. The concrete material, curing, protection, and placement for all curb, combination curb and gutter or, depressed curb and gutter shall meet the requirements of Articles 606, 1020, 1021, 1022, and 1023 of the State of Illinois "Standard Specifications for Road and Bridge Construction", latest edition. Membrane curing and concrete sealing shall be accompanied by W.R. Meadows CS-309 Cure and Seal or approved equal like Okon S-20. If the forecast indicates temperatures below 32° F, protection methods shall be installed in accordance with the Standard Specifications for Road and Bridge Construction and shall be approved by the City Engineer.
3. The minimum longitudinal curb slope shall be 0.40%.
4. Cuts into the existing curb shall be made full depth with full expansion joints drilled at each per Exhibit II-C-12 herein.

	REVISIONS		CURB AND GUTTER GENERAL NOTES		
	DATE:	BY:	SCALE:	CHECKED:	DRAWING NUMBER
	01/2011	jhs			
	02/2013	DG			
			DATE:	DRAWN:	EXHIBIT II-C-5
			03/08	J. MOORE	