



REFER TO THE STANDARD SPECIFICATIONS FOR IMPROVEMENTS FOR CORPORATION COUPLING, BUFFALO BOX, CURB BOX, AND PIPE MATERIAL, TYPE, MANUFACTURE, AND SIZES.

NOTES:

1. WHEN WATERMAIN IS LOCATED WITHIN AN EASEMENT RATHER THAN THE PUBLIC RIGHT-OF-WAY, THE BUFFALO-BOXES MUST ALSO BE LOCATED WITHIN THE EASEMENT AND WITHIN 2' OF THE WATERMAIN.



REVISIONS

DATE:	BY:
02-26-20	DGoewey
07-07-22	CArmin

TYPICAL WATER SERVICE
TAP AND BOX

SCALE:	CHECKED:	DRAWING NUMBER
NTS	DF	EXHIBIT III-C-6
DATE:	DRAWN:	
06/02	NM	