



SECTIONAL VIEW

\*\* MINIMUM DIMENSION ACCORDING TO THE STANDARD SPECIFICATIONS FOR WATER & SEWER MAIN CONSTRUCTION ILLINOIS, CURRENT EDITION

NOTES:

- 1) For sizes larger than 16", special design will be required.
- 2) In lieu of installing stainless steel rods, the mechanical joints can be restrained with the MegaLug Series 1100 as manufactured by EBBA Iron Inc, or approved equal. Also, the bell and spigot joints shall be restrained on either side of the mechanical joints by EBBA Iron 1700 series restraint or approved equal and the restraint distance shall be in accordance with Exhibits III-C-9 and III-C-10.



REVISIONS	
DATE: 04/18	BY: DGoewey

WATER MAIN LOWERING DETAIL		
SCALE: NOT TO SCALE	CHECKED: DF	DRAWING NUMBER: <b>EXHIBIT III-C-8</b>
DATE: 1/04	DRAWN: SAZ	