



NOTES:

① IDENTIFY LOCATION OF SERVICE CONNECTION. DEPLOY AND MAINTAIN ALL NECESSARY TRAFFIC CONTROL. EXCAVATE AND EXPOSE THE CORPORATION STOP.

IF CORPORATION STOP IS IN GOOD CONDITION, TURN TO THE OFF POSITION AND REMOVE SERVICE LINE. INSERT BRASS DISC AND SCREW ON COMPRESSION NUT.

IF CORPORATION STOP IS LEAKING, CLEAN MAIN, REMOVE CORPORATION STOP, AND INSTALL CITY FURNISHED REPAIR SLEEVE.

AFTER ALL WORK IS INSPECTED, BACKFILL AND RESTORE THE AREA PER APPROPRIATE CITY STANDARD SPECIFICATION.

② REMOVE UPPER SECTION OF B-BOX (3' MIN.) OR REMOVE B-BOX AND CURB STOP.



REVISIONS	
DATE: 04-18	BY: DGoewey

WATER SERVICE ABAN - Type A

SCALE: NOT TO SCALE	CHECKED: JB
DATE: 04/17	DRAWN: DG

DRAWING NUMBER: EXHIBIT III-G-1
