



NOTES:

- ① IDENTIFY LOCATION OF SERVICE CONNECTION. DEPLOY AND MAINTAIN ALL NECESSARY TRAFFIC CONTROL. EXCAVATE AND EXPOSE THE EXISTING TEE.
- ② IF TEE HAS LEAD CONNECTIONS, OR IS IN POOR CONDITION, REMOVE AND REPLACE WITH NEW CL-52 D.I.P. AND APPROPRIATE FITTINGS WITH RETAINER GLANDS.
- ③ IF TEE IS MECHANICAL AND CAN SUCCESSFULLY BE CAPPED AND PLUGGED, REMOVE SERVICE LINE AND INSTALL M.J. CAP OR PLUG. ENDS OF ABANDONED SERVICE SHALL BE PLUGGED WITH NON-SHRINK GROUT.
- ④ IDENTIFY LOCATION OF VALVE BOX OR VAULT. REMOVE VALVE BOX AND EXTENSION (UPPER 3' MIN.) OR REMOVE FRAME, LID AND A MINIMUM OF 4' OF THE EXISTING VAULT, FILL STRUCTURE WITH APPROVED BACKFILL.

AFTER ALL WORK IS INSPECTED, BACKFILL AND RESTORE THE AREA PER APPROPRIATE CITY STANDARD SPECIFICATION.



REVISIONS	
DATE: 05-18	BY: DGoewey

WATER SERVICE ABAN - Type C

SCALE: NOT TO SCALE	CHECKED: JB
DATE: 04/17	DRAWN: DG

DRAWING NUMBER: EXHIBIT III-G-3
