

FTNK – COMMERCIAL TANK - APPLICATION FORM

<p>FOR OFFICIAL USE ONLY</p> <p>PERMIT APPLICATION NO. 1 —</p> <p>SUBMITTED _____ / /</p> <p>NOTIFIED _____ / /</p> <p>ZONING _____</p>	<p style="text-align: center;">TOTAL FEE</p> <p>_____</p> <p>BLDG _____</p> <p>PLRV _____</p>	 <p>DIVISION OF BUILDING & PERMITS 77 S BROADWAY AURORA, ILLINOIS 60505</p>
<p>WEB www.aurora-il.org</p> <p>FAX (630) 256-3139</p> <p>TELEPHONE (630) 256-3130</p>	<p>DIVISION OF BUILDING & PERMITS 77 S BROADWAY AURORA, ILLINOIS 60505</p>	

LAND / PARCEL INFORMATION

PROPERTY ADDRESS _____

SUBDIVISION _____ **UNIT / PHASE #** _____ **LOT #** _____

COUNTY KANE DuPAGE **TOWNSHIP** 11 12 04 **TOWNSHIP SECTION #** _____
(CHECK ONE) KENDALL WILL (CIRCLE ONE) 14 15 07

(Call tax assessor's office with questions) 03 01 **BLOCK # (if known)** _____ **LOT# (if known)** _____

PROPERTY OWNER & CONTACT NAME _____

OWNER'S ADDRESS _____

PHONE # () _____

FAX # () _____

E-MAIL _____

TENANT & CONTACT NAME _____

ADDRESS _____

PHONE # () _____

FAX # () _____

E-MAIL _____

ZONING INFORMATION

Zoning (CHECK ONE) R-1 R-2 R-3 PDD

Classification R-4 R-4A R-5 R-5A


B-1 B-2 B-3 B-B

SPECIAL USE M-1 M-2

(CHECK IF APPLICABLE) O ORI RD PDD

DC DF C.O.A. Required

PLOT PLAN SKETCH w/ SETBACK INFORMATION



TANK INFORMATION

TEMPORARY TANK? YES NO

PERMANENT TANK? YES NO

UNDERGROUND TANK?? YES NO
REQUIRES PERMIT FROM STATE FIRE MARSHAL'S OFFICE.

ABOVE GROUND TANK? YES NO
REQUIRES PERMIT FROM STATE FIRE MARSHAL'S OFFICE.

LIQUID PROPANE GAS (LPG)? YES NO

CONTRACTOR REGISTRATION INFORMATION

GENERAL CONTRACTOR (Check primary contact)
CITY OF AURORA
G.C. REGISTRATION # _____ - _____

BUSINESS NAME _____
CONTACT NAME _____
ADDRESS _____
CITY, STATE, ZIP _____
N/A PHONE () _____ - _____
FAX () _____ - _____
E-MAIL _____

ELECTRICAL CONTRACTOR (primary contact)
CITY OF AURORA
ELECT. REGISTRATION # _____ - _____

BUSINESS NAME _____
CONTACT NAME _____
ADDRESS _____
CITY, STATE, ZIP _____
N/A PHONE () _____ - _____
FAX () _____ - _____
E-MAIL _____

PLUMBING CONTRACTOR (primary contact)
CITY OF AURORA
PLUMBING REGISTRATION # _____ - _____

BUSINESS NAME _____
CONTACT NAME _____
ADDRESS _____
CITY, STATE, ZIP _____
N/A PHONE () _____ - _____
FAX () _____ - _____
E-MAIL _____

CERTIFICATION

This is an application only. Completion of this application does NOT entitle the commencement of construction. I, (the applicant) agree to conform to all applicable laws of the City of Aurora. I also agree that all work performed will be in accordance with the plans and specifications as set forth in the approved permit. I understand that the approval of this application and issuance of a permit does not obviate the need to comply with all applicable laws and ordinances. I agree to hold harmless and indemnify the City of Aurora for any claim against the City as the result of any act of commission or omission by or on behalf of the undersigned, his/her agent, principle, contractor, subcontractor or supplier. I the undersigned am the Owner or a duly contracted representative of the owner of said property.

CONTRACTOR _____
(PRINT)

CONTRACTOR _____
(SIGNATURE)

OR

OWNER _____
(PRINT)

OWNER _____
(SIGNATURE)

MECHANICAL CONTRACTOR (primary contact)
CITY OF AURORA
HVAC REGISTRATION # _____ - _____

BUSINESS NAME _____
CONTACT NAME _____
ADDRESS _____
CITY, STATE, ZIP _____
N/A PHONE () _____ - _____
FAX () _____ - _____
E-MAIL _____

SCOPE OF WORK**APPLICATION REQUIREMENTS FOR TANK(S)**

The following items shall constitute a **complete building permit submittal**. Upon submittal acceptance, a permit application number shall be issued to the applicant all future contact with the Building and Permits Division will require this number. At time of submittal one project contact, shall be identified by the applicant (please check the appropriate party as the "primary contact" on the application form). All correspondence between City of Aurora Division of Building and Permits and the applicant will be directed to this individual.

SUBMITTALS TO THE BUILDING AND PERMITS DIVISION ARE INDICATED BELOW. COLLATE YOUR SUBMITTAL INTO TWO SETS

The storage of flammable and combustible liquids shall comply with chapter 57 of the 2015 International Fire Code. A separate permit from the Illinois State Fire Marshal shall be submitted with the application.

The storage of Liquid Propane Gas (LPG) shall comply with Chapter 61 of the 2015 International Fire Code. A separate permit from the Illinois State Fire Marshal is required for singular tanks of greater than 2,000 gallons capacity or multiple tanks with an aggregate capacity of 4,000 gallons or any size tank used to dispense LPG in to smaller cylinders or vehicles.

The following items need to be documented on the submitted plan.

- 1) Above ground containers of LP gas shall be a minimum distance of 10 feet from all buildings or lot lines of adjoining property 2015 IFC Section 6104
- 2) LP containers shall be kept a minimum of 10 feet from weeds, grass brush, trash or other combustible materials. 2015 IFC Section 6107.3
- 3) The minimum separation between multiple LP tanks is three feet. 2015 IFC Table 6104.3
- 4) Protect containers from vehicles. All (LPG) containers and associated regulators and piping that are exposed to vehicular traffic, or located with-in 25 feet of a road way or parking lot shall be protected from vehicle damage. Vehicle impact protection shall consist of the installation of posts constructed of steel not less than 4 inch in diameter and concrete filled and set not less than 36 inches deep in a concrete footing not less than 15 inches in diameter and spaced not more than 4 feet between posts. Or, provide a physical barrier a minimum of 36 inches high that can resist a force of 12000 pounds applied at a point 36 inches above the adjacent ground surface. 2015 IFC Section 6107.4 and Section 312

A separate permit is required the State of Illinois Fire Marshal's office for the installation of above ground storage tanks of flammable and combustible liquids in excess of 110 gallons.

Contact Illinois State Fire Marshal's Office; Division of Chemical and petroleum safety.

In addition Chapter 50 and chapter 57 of the 2015 International Fire Code are applicable including but not limited to:

- Vent piping. Vent piping for storage tanks shall be located such that the vapors are released at a point outside of the building not less than 12 feet above the adjacent ground level and provided with flame arrester.)
- Overfill protection provided. A means of notifying the person filling that the fluid level has reached 90% of tank capacity by providing an audible alarm, visual alarm or a tank level gauge marked at 90%.